



# CERTIFICATE

No. Z10 08 04 60643 003

**Holder of Certificate:** **RTP Corporation**  
 1834 SW 2nd Street  
 Pompano Beach FL 33069-4325  
 USA

**Factory(ies):** 60643

**Certification Mark:**



**Product:** **Safety Related Programmable Electronic System**

**Model(s):** **RTP2500**

**Parameters:**

Option 1:	
Operating Voltage:	18-36VDC
Input Current:	max 10A/24VDC
Option 2:	
Operating Voltage:	85-250VAC
Input Current:	max 3.2A/85VAC
Option 3:	
Operating Voltage:	100-140VDC
Input Current:	max 3.2A/100VDC
Operation Temperature:	-20°C to +60°C

**Tested according to:**

- IEC 61508-1: 1998 (SIL 1-3)
- (to the extent applicable)
- IEC 61508-2: 2000 (SIL 1-3)
- IEC 61508-3: 1998 (SIL 1-3)
- IEC 61508-4: 1998 (SIL 1-3)
- IEC 61511: 2003 (to the extent applicable)
- EN 61131-2: 2003
- EN 54-2: 1997 (Chapter 13)

The listed product was tested on a voluntary basis and complies with the relating standards or directives. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

**Test report no.:** RP67981C

**Date,** 2008-05-05

Page 1 of 1

